



Fluids for electrotechnical applications—Unused mineral insulating oils for transformers and switchgear (IEC 60296, Ed. 4.0 (2012), MOD)



This Australian Standard® was prepared by Committee EL-008, Power Transformers. It was approved on behalf of the Council of Standards Australia on 13 March 2017. This Standard was published on 8 May 2016.

The following are represented on Committee EL-008:

- Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Australian Institute of Petroleum
 - Electricity Engineers Association (New Zealand)
 - Energy Efficiency and Conservation Authority of New Zealand
 - Energy Networks Australia
 - Engineers Australia
 - Rail Industry Safety and Standards Board
-

This Standard was issued in draft form for comment as DR AS 60296:2016.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard®

**Fluids for electrotechnical
applications—Unused mineral insulating
oils for transformers and switchgear
(IEC 60296, Ed. 4.0 (2012), MOD)**

Originated as AS C62—1935.
Previous edition AS 1767.1—1999.
This edition 2017.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 752 8

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-008, Power Transformers, to supersede AS 1767.1—1999, *Insulating liquids*, Part 1: *Specification for unused mineral insulating oils for transformers and switchgear*.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide guidance to assist users when specifying unused mineral insulating oils for use in transformers and switchgear.

This Standard is an adoption with national modifications and has been reproduced from IEC 60296:2012, *Fluids for electrotechnical applications—Unused mineral insulating oils for transformers and switchgear* and has been varied as indicated in Appendix ZZ to take account of Australian conditions. For the purpose of this Standard, the IEC text and tables are amended, supplemented or replaced as set out in Appendix ZZ.

The title and designation of this Australian Standard has been changed to align with the IEC standard on which it is based.

This Standard is structured in the following layout:

- (a) Preface.
- (b) IEC 60296 (unedited from the Scope to the final Clause of the IEC Standard).
- (c) Appendix ZZ—Australian variations to the IEC Standard.

As this Standard is reproduced from an International Standard, the following applies:

- (i) In the source text ‘this International Standard’ should read ‘this Australian Standard’.
- (ii) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian/New Zealand Standard</i>
IEC	AS/NZS
60076 Power transformers	60076 Power transformers
60076-2 Part 2: Temperature rise for liquid-immersed transformers	60076.2 Part 2: Temperature rise for liquid-immersed transformers (IEC 60076-2, Ed. 3.0 (2011) MOD)
	AS
	1767 Insulating liquids
60156 Insulating liquids—Determination of the breakdown voltage at power frequency—Test method	1767.2.1 Part 2: Test methods, Method 2.1: Determination of the breakdown voltage at power frequency
60247 Insulating liquids—Measurement of relative permittivity, dielectric dissipation factor (tan δ) and d.c. resistivity	1767.2.2 Part 2: Test methods, Methods 2.2: Measurement of relative permittivity, dielectric dissipation factor (tan δ) and d.c. resistivity.

IEC		AS	
60422	Mineral insulating oils in electrical equipment—Supervision and maintenance guidance	60422*	Mineral insulating oils in electrical equipment—Supervision and maintenance guidance (IEC 60422:2013, MOD)
60475	Method of sampling insulating liquids dielectrics	1767	Insulating liquids
		1767.2.3	Part 2: Test methods Method 2.3: Method of sampling liquid dielectrics
60814	Insulating liquids—Oil-impregnated paper and pressboard—Determination of water by automatic coulometric Karl Fischer titration	1767.2.8	Method 2.8: Test methods—Determination of water in oil-impregnated paper and pressboard by automatic coulometric Karl Fischer titration (IEC 60814, Ed.2.0 (1997) MOD)

Only normative references that have been adopted as Australian or Australian/New Zealand Standard have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is only for information and guidance.

* To be published.

CONTENTS

1	Scope.....	7
2	Normative references	7
3	Terms and definitions	9
4	Properties of oil	10
4.1	Functional properties.....	10
4.2	Refining and stability	10
4.3	Performance.....	10
4.4	Health, safety and environment (HSE) properties	10
5	Classification, identification, general delivery requirements and sampling.....	11
5.1	Classification.....	11
5.1.1	Classes	11
5.1.2	Antioxidant additive (inhibitor) content.....	11
5.1.3	Lowest cold start energizing temperature (LCSET)	11
5.2	Requirements.....	11
5.3	Miscibility	11
5.4	Identification and general delivery requirements.....	11
5.5	Sampling	12
6	Properties, their significance and test methods.....	12
6.1	Viscosity.....	12
6.2	Pour point	12
6.3	Water content.....	12
6.4	Breakdown voltage	13
6.5	Dielectric dissipation factor (DDF)	13
6.6	Appearance.....	13
6.7	Acidity.....	13
6.8	Interfacial tension (IFT)	13
6.9	Sulphur content	13
6.10	Corrosive and potentially corrosive sulphur	13
6.11	Additives (see 3.4)	14
6.11.1	General	14
6.11.2	Antioxidant additives (see 3.5).....	14
6.11.3	Metal passivators	14
6.11.4	Pour point depressants.....	15
6.12	Oxidation stability.....	15
6.13	Gassing tendency.....	15
6.14	Electrostatic charging tendency (ECT).....	15
6.15	Flash point	15
6.16	Density.....	15
6.17	Polycyclic aromatic content (PCAs)	16
6.18	Polychlorinated biphenyl content (PCBs)	16
6.19	2-Furfural (2-FAL) and related compounds content.....	16
6.20	Particle content	16

	<i>Page</i>
6.21 DBDS content	16
6.22 Stray gassing of oil.....	16
7 Specific requirements for special applications	18
7.1 Higher oxidation stability and low sulphur content	18
7.2 Electrostatic charging tendency (ECT).....	18
7.3 Gassing tendency.....	18
Annex A (informative) Potentially corrosive sulphur	19
Bibliography.....	21
Table 1 – Maximum viscosity and pour point of transformer oil at lowest cold start energizing temperature (LCSET).....	12
Table 2 – General specifications	17

INTRODUCTION

This International Standard does not purport to address all the safety problems associated with its use. It is the responsibility of the user of the standard to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

The mineral insulating oils which are the subject of this standard should be handled with due regard to personal hygiene. Direct contact with the eyes may cause irritation. In the case of eye contact, irrigation with copious quantities of clean running water should be carried out and medical advice sought. Some of the tests specified in this standard involve the use of processes that could lead to a hazardous situation. Attention is drawn to the relevant standard for guidance.

This standard is applicable to mineral insulating oils, chemicals and used sample containers. The disposal of these items should be carried out according to local regulations with regard to their impact on the environment. Every precaution should be taken to prevent release of mineral insulating oil into the environment.

This is a free preview. Purchase the entire publication at the link below:

AS 60296 : 2017 : EN : COMBINED PDF

-
- ⊙ Looking for additional Standards? Visit SAI Global Infostore
 - ⊙ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-

Need to speak with a Customer Service Representative - Contact Us