



**Mineral insulating oils in electrical
equipment—Supervision and
maintenance guidance
(IEC 60422, Ed. 4.0 (2013) MOD)**



This Australian Standard® was prepared by Committee EL-008, Power Transformers. It was approved on behalf of the Council of Standards Australia on 26 February 2017. This Standard was published on 14 March 2017.

The following are represented on Committee EL-008:

- Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Australian Institute of Petroleum
 - Electricity Engineers Association, New Zealand
 - Energy Efficiency and Conservation Authority of New Zealand
 - Energy Networks Australia
 - Engineers Australia
 - Rail Industry Safety and Standards Board
-

This Standard was issued in draft form for comment as DR AS 60422:2016.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard®

**Mineral insulating oils in electrical
equipment—Supervision and
maintenance guidance
(IEC 60422, Ed. 4.0 (2013) MOD)**

Originated as AS CC11—1965.
Previous edition AS 1883—1992.
Revised and redesignated as AS 60422:2017.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 701 6

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-008, Power Transformers, to supersede AS 1883—1992, *Guide to maintenance and supervision of insulating oils in service*. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to give guidance to assist users of electrical power equipment filled with or immersed in mineral insulating oils supplied in accordance with AS 1767.1, *Insulating liquids, Part 1: Specification for unused mineral insulating oils for transformers and switchgear*, in monitoring and evaluating the condition of oil by recommended standardized tests and procedures and maintaining the oil in serviceable conditions by reconditioning and reclaiming.

It is recognized that oils in service may become contaminated with polychlorinated biphenyls (PCBs). It is not the intention of this Standard to specify the degree of contamination which may be permitted. Reference needs to be made to the appropriate legislation.

This Standard is an adoption with national modifications and has been reproduced from IEC 60422, Ed. 4.0 (2013), *Mineral insulating oils in electrical equipment—Supervision and maintenance guidance*, and its Corrigendum 1 (2013), and has been varied as indicated in Appendix ZZ to take account of Australian conditions.

The title and designation of this Australian Standard have been changed to align with the IEC Standard on which it is based.

This Standard is structured in the following layout:

- (a) Preface.
- (b) IEC 60422 and its Corrigendum 1 (2013) (unedited from the Scope to the final clause of the IEC Standard).
- (c) Appendix ZZ—Australian variations to the IEC Standard.

As this Standard is reproduced from an International Standard, the following applies:

- (i) In the source text ‘this International Standard’ should read ‘this Australian Standard’.
- (ii) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian Standard</i>	
IEC	AS	
60156 Insulating liquids—Determination of the breakdown voltage at power frequency—Test method	1767 1767.2.1	Insulating liquids Part 2: Test methods Method 2.1: Determination of the breakdown voltage at power frequency
60247 Insulating liquids—Measurement of relative permittivity, dielectric dissipation factor ($\tan \delta$) and d.c. resistivity	1767.2.2	Method 2.2: Test methods— Measurement of relative permittivity, dielectric dissipation factor ($\tan \delta$) and d.c. resistivity
60296 Fluids for electrotechnical applications—Unused mineral insulating oils for transformers and switchgear	1767.1	Part 1: Specification for unused mineral insulating oils for transformers and switchgear

IEC 60475	Method of sampling liquid dielectrics	AS 1767.2.3	Part 2: Test methods Method 2.3: Method of sampling liquid dielectrics
60666	Detection and determination of specified additives in mineral insulating oils	1767.2.4	Part 2: Test methods Method 2.4: Detection and determination of specified anti-oxidant additives in insulating oils
60814	Insulating liquids—Oil-impregnated paper and pressboard—Determination of water by automatic coulometric Karl Fischer titration	1767.2.8	Method 2.8: Test methods—Determination of water in oil-impregnated paper and pressboard by automatic coulometric Karl Fischer titration (IEC 60814, Ed. 2.0 (1997) MOD)
61125	Unused hydrocarbon based insulating liquids—Test methods for evaluating the oxidation stability	1767.2.5	Part 2: Test methods Method 2.5: Unused hydrocarbon-based insulating liquids—Test methods for evaluating the oxidation stability
61619	Insulating liquids—Contamination by polychlorinated biphenyls (PCBs)—Method of determination by capillary column gas chromatography	1767.2.7	Part 2: Test methods Method 2.7: Determination of PCB contamination in insulating liquids by capillary column gas chromatography—Identification of congeners

Only international references that have been adopted as Australian Standards have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is for information and guidance only.

CONTENTS

1	Scope	8
2	Normative references	8
3	Terms and definitions	9
4	Properties and deterioration/degradation of oil	10
5	Oil tests and their significance	11
5.1	General	11
5.2	Colour and appearance	12
5.3	Breakdown voltage	12
5.4	Water content	12
5.4.1	General	12
5.4.2	Water in oil	12
5.4.3	Water content in the oil/paper-system	14
5.4.4	Interpretation of results	15
5.5	Acidity	15
5.6	Dielectric dissipation factor (DDF) and resistivity	15
5.7	Inhibitor content and oxidation stability	18
5.7.1	Oxidation stability	18
5.7.2	Monitoring of uninhibited oils	18
5.7.3	Monitoring of inhibited oils	18
5.8	Sediment and sludge	18
5.9	Interfacial tension (IFT)	19
5.10	Particle count	19
5.11	Flash point	19
5.12	Compatibility of insulating oils	20
5.13	Pour point	20
5.14	Density	20
5.15	Viscosity	20
5.16	Polychlorinated biphenyls (PCBs)	21
5.17	Corrosive sulphur	21
5.18	Dibenzyl disulphide (DBDS)	22
5.19	Passivator	22
6	Sampling of oil from equipment	22
7	Categories of equipment	23
8	Evaluation of mineral insulating oil in new equipment	23
9	Evaluation of oil in service	24
9.1	General	24
9.2	Frequency of examination of oils in service	25
9.3	Testing procedures	26
9.3.1	General	26
9.3.2	Field tests	26
9.3.3	Laboratory tests	27
9.4	Classification of the condition of oils in service	27
9.5	Corrective action	27

10	Handling and storage	32
11	Treatment.....	33
11.1	WARNING	33
11.2	Reconditioning	34
11.2.1	General	34
11.2.2	Reconditioning equipment	35
11.2.3	Application to electrical equipment	36
11.3	Reclaiming	37
11.3.1	General	37
11.3.2	Reclaiming by percolation.....	37
11.3.3	Reclaiming by contact	38
11.3.4	Renewal of additives	38
11.4	Decontamination of oils containing PCBs	38
11.4.1	General	38
11.4.2	Dehalogenation processes using sodium and lithium derivatives	38
11.4.3	Dehalogenation processes using polyethylene glycol and potassium hydroxide (KPEG).....	39
11.4.4	Dehalogenation in continuous mode by closed circuit process	39
12	Replacement of oil in electrical equipment.....	39
12.1	Replacement of oil in transformers rated below 72,5 kV and in switchgear and associated equipment.....	39
12.2	Replacement of oil in transformers rated 72,5 kV and above	39
12.3	Replacement of oil in electrical equipment contaminated with PCB.....	40
13	Passivation.....	40
Annex A	(informative) Evaluating water in oil and insulation.....	41
Annex B	(informative) Particles.....	43
Annex C	(informative) Test method for determination of sediment and sludge.....	44
Bibliography	45
Figure 1	– Example of variation in saturation water content with oil temperature and acidity for insulating oil originally conforming to IEC 60296.....	14
Figure 2	– Example of variation of resistivity with temperature for insulating oils.....	17
Figure A.1	– Typical correction factors.....	41
Table 1	– Tests for in-service mineral insulating oils	11
Table 2	– Categories of equipment	23
Table 3	– Recommended limits for mineral insulating oils after filling in new electrical equipment prior to energization.....	24
Table 4	– Recommended frequency of testing ^a	26
Table 5	– Application and interpretation of tests (1 of 4)	28
Table 6	– Summary of typical actions.....	32
Table 7	– Conditions for processing inhibited and/ or passivator containing mineral insulating oils.....	35
Table A.1	– Guidelines for interpreting data expressed in per cent saturation	42
Table B.1	– Typical contamination levels (particles) encountered on power transformer insulating oil as measured using IEC 60970.....	43

INTRODUCTION

Insulating mineral oils are used in electrical equipment employed in the generation, transmission, distribution and use of electrical energy, so that the amount of oil in service, worldwide, amounts to hundreds of millions of kilograms.

Monitoring and maintaining oil quality is essential to ensure the reliable operation of oil-filled electrical equipment. Codes of practice for this purpose have been established by electrical power authorities, power companies and industries in many countries.

A review of current experience reveals a wide variation of procedures and criteria. It is possible, however, to compare the value and significance of standardized oil tests and to recommend uniform criteria for the evaluation of test data.

If a certain amount of oil deterioration (by degradation or contamination) is exceeded, there is inevitably some erosion of safety margins and the question of the risk of premature failure should be considered. While the quantification of the risk can be very difficult, a first step involves the identification of potential effects of increased deterioration. The philosophy underlying this standard is to furnish users with as broad a base of understanding of oil quality deterioration as is available, so that they can make informed decisions on inspection and maintenance practices.

Unused mineral oils are limited resources and should be handled with this in mind. Used mineral oils are, by most regulations, deemed to be controlled waste. If spills occur this may have a negative environmental impact especially if the oil is contaminated by persistent organic pollutants such as polychlorinated biphenyls (PCBs).

This International Standard, whilst technically sound, is mainly intended to serve as a common basis for the preparation of more specific and complete codes of practice by users in the light of local circumstances. Sound engineering judgement will have to be exerted in seeking the best compromise between technical requirements and economic factors.

Reference should also be made to instructions from the equipment manufacturer.

General caution

This International Standard does not purport to address all the safety problems associated with its use. It is the responsibility of the user of this standard to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

The mineral oils and oil additives which are the subject of this standard should be handled with due regard to personal hygiene. Direct contact with the eyes may cause slight irritation. In the case of eye contact, irrigation with copious quantities of clean running water should be carried out and medical advice sought. For more information, refer to the safety data sheet provided by the manufacturer. Some of the tests specified in this standard involve the use of processes that could lead to a hazardous situation. Attention is drawn to the relevant standard for guidance.

Environment

This standard is applicable to mineral oils, chemicals and used sample containers.

Attention is drawn to the fact that, at the time of writing this standard, some mineral oils in service are known to be contaminated to some degree by PCBs.

Because of this, safety countermeasures should be taken to avoid risks to workers, the public and the environment during the life of the equipment, by strictly controlling spills and emissions. Disposal or decontamination of these oils should be carried out strictly according to local regulations. Every precaution should be taken to prevent release of mineral oil into the environment.

This is a free preview. Purchase the entire publication at the link below:

AS 60422 : 2017 : EN : COMBINED PDF

-
- ⊙ Looking for additional Standards? Visit SAI Global Infostore
 - ⊙ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-

Need to speak with a Customer Service Representative - Contact Us