

Australian Standard™

**Communication networks and systems
in substations**

**Part 7.4: Basic communication structure
for substation and feeder equipment—
Compatible logical node classes and
data classes**



This Australian Standard was prepared by Committee EL-050, Power System Control and Communication. It was approved on behalf of the Council of Standards Australia on 15 August 2005.
This Standard was published on 21 September 2005.

The following are represented on Committee EL-050:

Australian Electrical and Electronic Manufacturers Association
Commerce Queensland
Energy Networks Association
Engineers Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 05210.

Australian Standard™

**Communication networks and systems
in substations**

**Part 7.4: Basic communication structure
for substation and feeder equipment—
Compatible logical node classes and
data classes**

First published as AS 61850.7.4—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 6853 9

PREFACE

This Standard was prepared by the Standards Australia Committee EL-050, Power System Control and Communication.

The objective of this Standard is to provide users and manufacturers of substation automation equipment with specifications for the information model of devices and functions related to substation applications. In particular, it specifies the compatible logical node names and data names for communication between Intelligent Electronic Devices (IED). This includes the relationship between Logical Nodes and Data.

This Standard is identical with, and has been reproduced from IEC 61850-7-4, Ed.1.0 (2003), *Communication networks and systems in substations – Part 7.4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes*.

This Standard is Part of *Communication networks and systems in substations*. The series consists of the following:

- Part 1: Introduction and overview
- Part 2: Glossary
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and device models
- Part 6: Configuration description language for communication in electrical substations related to IEDs
- Part 7.1: Basic communication structure for substation and feeder equipment—Principles and models
- Part 7.2: Basic communication structure for substation and feeder equipment—Abstract communication service interface (ACSI)
- Part 7.3: Basic communication structure for substation and feeder equipment—Common data classes
- Part 7.4: Basic communication structure for substation and feeder equipment—Compatible logical node classes and data classes (this Standard)
- Part 8.1: Specific communication service mapping (SCSM)—Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3
- Part 9.1: Specific communication service mapping (SCSM)—Sampled values over serial unidirectional multidrop point to point link
- Part 9.2: Specific communication service mapping (SCSM)—Sampled values over ISO/IEC 8802-3

As this Standard is reproduced from an International Standard, the following applies:

Its number does not appear on each page of text and its identity is shown only on the cover and title page.

In the source text 'IEC/TR 61850-7-4' should read 'AS 61850.7.4'.

A full point should be substituted for a comma when referring to a decimal marker.

Any French text on figures should be ignored.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

INTRODUCTION.....	viii
1 Scope.....	1
2 Normative references.....	2
3 Terms and definitions.....	3
4 Abbreviated terms.....	3
5 Logical node classes.....	7
5.1 Logical Node groups.....	7
5.2 Interpretation of Logical Node tables.....	7
5.3 System Logical NodesLN Group: L.....	8
5.3.1 General.....	8
5.3.2 LN: Physical device informationName: LPHD.....	9
5.3.3 Common Logical Node.....	9
5.3.4 LN: Logical node zeroName: LLN0.....	10
5.4 Logical Nodes for protection functionsLN Group: P.....	10
5.4.1 Modelling remarks.....	10
5.4.2 LN: DifferentialName: PDIF.....	12
5.4.3 LN: Direction comparisonName: PDIR.....	13
5.4.4 LN: DistanceName: PDIS.....	13
5.4.5 LN: Directional overpowerName: PDOP.....	14
5.4.6 LN: Directional underpowerName: PDUP.....	15
5.4.7 LN: Rate of change of frequencyName: PFRC.....	15
5.4.8 LN: Harmonic restraintName: PHAR.....	16
5.4.9 LN: Ground detectorName: PHIZ.....	16
5.4.10 LN: Instantaneous overcurrentName: PIOC.....	16
5.4.11 LN: Motor restart inhibitionName: PMRI.....	17
5.4.12 LN: Motor starting time supervisionName: PMSS.....	17
5.4.13 LN: Over power factorName: POPF.....	18
5.4.14 LN: Phase angle measuringName: PPAM.....	18
5.4.15 LN: Protection schemeName: PSCH.....	19
5.4.16 LN: Sensitive directional earthfaultName: PSDE.....	19
5.4.17 LN: Transient earth faultName: PTEF.....	20
5.4.18 LN: Time overcurrentName: PTOC.....	20
5.4.19 LN: OverfrequencyName: PTOF.....	21
5.4.20 LN: OvervoltageName: PTOV.....	21
5.4.21 LN: Protection trip conditioningName: PTRC.....	22
5.4.22 LN: Thermal overloadName: PTTR.....	22
5.4.23 LN: UndercurrentName: PTUC.....	23
5.4.24 LN: UndervoltageName: PTUV.....	24
5.4.25 LN: Underpower factorName: PUPF.....	24
5.4.26 LN: UnderfrequencyName: PTUF.....	24
5.4.27 LN: Voltage controlled time overcurrentName: PVOC.....	25
5.4.28 LN: Volts per HzName: VVPH.....	25
5.4.29 LN: Zero speed or underspeedName: PZSU.....	26
5.5 Logical Nodes for protection related functionsLN Group: R.....	26
5.5.1 Modelling Remarks.....	26
5.5.2 LN: Disturbance recorder functionName: RDRE.....	27

5.5.3	LN: Disturbance recorder channel analogueName: RADR	28
5.5.4	LN: Disturbance recorder channel binaryName: RBDR	28
5.5.5	LN: Disturbance record handlingName: RDRS	29
5.5.6	LN: Breaker failureName: RBRF	29
5.5.7	LN: Directional elementName: RDIR	29
5.5.8	LN: Fault locatorName: RFLO	30
5.5.9	LN: Power swing detection/blockingName: RPSB	30
5.5.10	LN: AutoreclosingName: RREC	31
5.5.11	LN: Synchronism-check or synchronisingName: RSYN	32
5.6	Logical Nodes for controlLN Group: C	33
5.6.1	Modelling remarks	33
5.6.2	LN: Alarm handlingName: CALH	33
5.6.3	LN: Cooling group controlName: CCGR	33
5.6.4	LN: InterlockingName: CILO	34
5.6.5	LN: Point-on-wave switchingName: CPOW	34
5.6.6	LN: Switch controllerName: CSWI	35
5.7	Logical Nodes for generic referencesLN Group: G	35
5.7.1	LN: Generic automatic process controlName: GAPC	35
5.7.2	LN: Generic process I/OName: GGIO	36
5.7.3	LN: Generic security applicationName: GSAL	36
5.8	Logical Nodes for interfacing and archivingLN Group: I	36
5.8.1	LN: ArchivingName: IARC	36
5.8.2	LN: Human machine interfaceName: IHMI	37
5.8.3	LN: Telecontrol interfaceName: ITCI	37
5.8.4	LN: Telemonitoring interfaceName: ITMI	37
5.9	Logical Nodes for automatic controlLN Group: A	38
5.9.1	Modelling remarks	38
5.9.2	LN: Neutral current regulatorName: ANCR	38
5.9.3	LN: Reactive power controlName: ARCO	38
5.9.4	LN: Automatic tap changer controllerName: ATCC	39
5.9.5	LN: Voltage controlName: AVCO	40
5.10	Logical Nodes for metering and measurementLN Group: M	40
5.10.1	Modelling remarks	40
5.10.2	LN: Differential measurementsName: MDIF	41
5.10.3	LN: Harmonics or interharmonicsName: MHAI	41
5.10.4	LN: Non phase related harmonics or interharmonicsName: MHAN	43
5.10.5	LN: MeteringName: MMTR	44
5.10.6	LN: Non phase related MeasurementName: MMXN	45
5.10.7	LN: MeasurementName: MMXU	45
5.10.8	LN: Sequence and imbalanceName: MSQI	46
5.10.9	LN: Metering StatisticsName: MSTA	46
5.11	Logical Nodes for sensors and monitoringLN Group: S	47
5.11.1	Modelling remarks	47
5.11.2	LN: Monitoring and diagnostics for arcsName: SARC	47
5.11.3	LN: Insulation medium supervision (gas)Name: SIMG	48
5.11.4	LN: Insulation medium supervision (liquid)Name: SIML	48
5.11.5	LN: Monitoring and diagnostics for partial dischargesName: SPDC	49
5.12	Logical Nodes for switchgearLN Group: X	49
5.12.1	LN: Circuit breakerName: XCBR	49

5.12.2	LN: Circuit switchName: XSWI	50
5.13	Logical Nodes for instrument transformersLN Group: T	50
5.13.1	LN: Current transformerName: TCTR	50
5.13.2	LN: Voltage transformerName: TVTR	51
5.14	Logical Nodes for power transformersLN Group: Y	51
5.14.1	LN: Earth fault neutralizer (Petersen coil)Name: YEFN	51
5.14.2	LN: Tap changerName: YLTC	52
5.14.3	LN: Power shuntName: YPSH	52
5.14.4	LN: Power transformerName: YPTR	53
5.15	Logical Nodes for further power system equipmentLN Group: Z	53
5.15.1	LN: Auxiliary networkName: ZAXN	53
5.15.2	LN: BatteryName: ZBAT	54
5.15.3	LN: BushingName: ZBSH	54
5.15.4	LN: Power cableName: ZCAB	54
5.15.5	LN: Capacitor bankName: ZCAP	55
5.15.6	LN: ConverterName: ZCON	55
5.15.7	LN: GeneratorName: ZGEN	55
5.15.8	LN: Gas insulated lineName: ZGIL	56
5.15.9	LN: Power overhead lineName: ZLIN	56
5.15.10	LN: MotorName: ZMOT	56
5.15.11	LN: ReactorName: ZREA	57
5.15.12	LN: Rotating reactive componentName: ZRRC	57
5.15.13	LN: Surge arresterName: ZSAR	57
5.15.14	LN: Thyristor controlled frequency converterName: ZTCF	57
5.15.15	LN: Thyristor controlled reactive componentName: ZTCR	58
6	Data name semantics	58
Annex A (normative)	Extension rules	79
Annex B (informative)	Modelling examples	83
Annex C (informative)	Relationship between this standard and IEC 61850-5	91
Figure 1	– Overview of this standard	2
Figure 2	– LN Relationships	9
Figure B.1	– Fault current I_F in a compensated network with earth fault	83
Figure B.2	– Use of PSCH and PTRC	84
Figure B.3	– Use of MDIF and PDIF	85
Figure B.4	– Modelling of Disturbance Recorder	86
Figure B.5	– Examples for allocation of Logical Nodes to IEDs	86
Figure B.6	– Use of PDIR	87
Figure B.7	– Use of RREC	88
Table 1	– List of Logical Node Groups	7
Table 2	– Interpretation of Logical Node tables	7
Table 3	– Relation between IEC 61850-5 and IEC 61850-7-4 (this standard) for protection LNs	11
Table 4	– Relation between IEC 61850-5 and IEC 61850-7-4 for protection related LNs	26
Table 5	– Relation between IEC 61850-5 and IEC 61850-7-4 for control LNs	33
Table 6	– Relation between IEC 61850-5 and IEC 61850-7-4 for automatic control LNs	38
Table 7	– Relation between IEC 61850-5 and IEC 61850-7-4 for metering and measurement LNs	40

Table 8 – Relation between IEC 61850-5 and IEC 61850-7-4 for sensors and monitoring LNs.....	47
Table 9 – Description of Data.....	58
Table C.1 – Relationship between IEC 61850-5 and this standard for some miscellaneous LNs.....	91

INTRODUCTION

This part of IEC 61850 is a part of set of specifications (IEC 61850). IEC 61850 defines a substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks, implementations, and operating systems. The mapping of these abstract classes and services to communication stacks is outside the scope of IEC 61850-7-x and may be found in IEC 61850-8-x and in IEC 61850-9-x.

IEC 61850-7-1 gives an overview of this communication architecture. IEC 61850-7-3 defines common attribute types and common data classes related to substation applications. The attributes of the common data classes may be accessed using services defined in IEC 61850-7-2. These common data classes are used in this part to define the compatible data classes.

To reach interoperability, all data in the data model need a strong definition with regard to syntax and semantics. The semantics of the data is mainly provided by names assigned to logical nodes and data they contain, as defined in this part. Interoperability is easiest if as much as possible of the data are defined as mandatory. Because of different philosophies and technical features, settings were declared as optional in this edition of the standard. After some experience has been gained with this standard, this decision may be reviewed in an amendment or in the next revision of this part.

It should be noted that data with full semantics is only one of the elements required to achieve interoperability. Since data and services are hosted by devices (IED), a proper device model is needed along with compatible, domain specific services (see IEC 61850-7-2).

The compatible logical node name and data name definitions found in this part and the associated semantics are fixed. The syntax of the type definitions of all data classes are abstract definitions provided in IEC 61850-7-2 and IEC 61850-7-3. Not all features of logical nodes are listed in this part for example data sets and logs are covered in IEC 61850-7-2.

STANDARDS AUSTRALIA

Australian Standard
Communication networks and systems in substations
**Part 7.4: Basic communication structure for substation and feeder equipment—
Compatible logical node classes and data classes**

1 Scope

This part of IEC 61850 specifies the information model of devices and functions related to substation applications. In particular, it specifies the compatible logical node names and data names for communication between Intelligent Electronic Devices (IED). This includes the relationship between Logical Nodes and Data.

The Logical Node Names and Data Names defined in this document are part of the class model introduced in IEC 61850-7-1 and defined in IEC 61850-7-2. The names defined in this document are used to build the hierarchical object references applied for communicating with IEDs in substations and on distribution feeders. The naming conventions of IEC 61850-7-2 are applied in this part.

To avoid private, incompatible extension rules this part specifies normative naming rules for multiple instances and private extensions of Logical Node (LN) Classes and Data Names.

In Annex A, all rules are given (making use of examples) for:

- multiple instances of logical node classes by use of a LN instance identification (ID);
- multiple instances of data by use of a data instance ID;
- selecting data not included in LN out of the complete data name set;
- creating new logical node classes and data names.

In Annex B, examples are given for:

- the use of Logical Nodes in complex situations like line protection schemes;
- multiple instances of Logical Nodes with different levels of functionality.

This part does not provide tutorial material. It is recommended those parts IEC 61850-5 and IEC 61850-7-1 be read first, in conjunction with IEC 61850-7-3, and IEC 61850-7-2. This part does not discuss implementation issues. The relationship between this standard and IEC 61850-5 is outlined in Annex C.

This standard is applicable to describe device models and functions of substation and feeder equipment. The concepts defined in this standard may also be applied to describe device models and functions for:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation,
- information exchange for distributed automation, or
- information exchange for metering.

Figure 1 provides a general overview of this document.

This is a free preview. Purchase the entire publication at the link below:

AS 61850.7.4 : 2005 : EN PDF

-
- ⏪ Looking for additional Standards? Visit SAI Global Infostore
 - ⏩ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-

Need to speak with a Customer Service Representative - Contact Us