

Australian/New Zealand Standard™

**Liquid-chilling packages using the
vapour compression cycle**

**Part 1.1: Method of rating and testing
for performance—Rating**



AS/NZS 4776.1.1:2008

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee ME-086, Commercial Airconditioning Equipment. It was approved on behalf of the Council of Standards Australia on 9 September 2008 and on behalf of the Council of Standards New Zealand on 19 September 2008. This Standard was published on 14 November 2008.

The following are represented on Committee ME-086:

Airconditioning & Refrigeration Equipment Manufacturers Association of Australia
Australian Building Codes Board
Australian Greenhouse Office, Department of the Environment and Water Resources
Australian Institute of Refrigeration, Air Conditioning and Heating
Energy Efficiency and Conservation Authority of New Zealand
Engineers Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 07278.

Australian/New Zealand Standard™

Liquid-chilling packages using the vapour compression cycle

Part 1.1: Method of rating and testing for performance—Rating

First published as AS/NZS 4776.1.1:2008.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8935 8

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee ME-086, Commercial Air Conditioning. This document is based on ISO PWD 19298-1, *Liquid-chilling packages using the vapour compression cycle*, Part 1: *Method for rating for performance*.

This Standard is part of a series for liquid-chilling packages, as follows:

AS/NZS

- 4776 Liquid-chilling packages using the vapour compression cycle
- 4776.1.1 Part 1.1: Method of rating and testing for performance—Rating (this Standard)
- 4776.1.2 Part 1.2: Method of rating and testing for performance—Testing
- 4776.2 Part 2: Minimum energy performance standard (MEPS) and compliance requirements

Part 1.1 of the series (this Part) is published with the express approval of the Australian Greenhouse Office, the Australian State and Territory regulatory authorities, and the Energy Efficiency and Conservation Authority of New Zealand, and it is structured to be suitable for reference in legislation in Australia and New Zealand.

In order for a manufacturer to comply with this Standard, conformance to both Part 1.1 and Part 1.2 is required. Agencies or companies that offer testing services only may use Part 1.2 of the Standard. The Standard is intended for use as the basis for certification programs in various geographic regions. This Standard may also be used for customer-specific tests conducted in appropriate test facilities; however, it is not intended for field testing.

Acknowledgment is due to the Air-Conditioning, Heating, and Refrigeration Institute (AHRI) of the USA, whose Standards were reviewed during the development of this Standard. This Standard is a Joint Australian/New Zealand Standard and is not an AHRI Standard.

Statements expressed in mandatory terms in notes to figures are deemed to be requirements of this Standard.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 OBJECTIVE	4
3 NORMATIVE REFERENCES	4
4 DEFINITIONS.....	4
5 RATING REQUIREMENTS	6
6 PUBLISHED RATINGS.....	8
7 RATING TOLERANCES	10

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Liquid-chilling packages using the vapour compression cycle****Part 1.1: Method of rating and testing for performance—Rating****1 SCOPE**

This Standard sets out a procedure for rating liquid-chilling packages used in applications with temperatures as described in Clause 5.3 and as defined in Clause 4.12. This Standard covers air- and water-cooled liquid-chilling packages of cooling capacity 350 kW and above.

This Standard does not cover—

- (a) liquid-chilling packages driven by other than electric motors;
- (b) air-cooled liquid-chilling packages with centrifugal fans;
- (c) liquid-chilling packages with remote condensers; and
- (d) liquid-chilling packages for fluids other than water.

This Standard covers full-load and part-load ratings to allow for an energy analysis of the unit in different applications.

2 OBJECTIVE

The objective of this Standard is to establish methods of rating the performance of factory-made liquid-chilling packages using the vapour compression cycle.

3 NORMATIVE REFERENCES

The following referenced documents are indispensable for the application of this Standard:

AS/NZS

1677 Refrigerating systems

1677.1 Part 1: Refrigerant classification

ARI

550/590 Water chilling packages using the vapor compression cycle

4 DEFINITIONS

For the purpose of this Standard, the definitions below apply.

4.1 Air-cooled condenser

A refrigeration system component that condenses refrigerant vapour by rejecting heat to air circulated over its heat transfer surface, causing a rise in the air temperature. Desuperheating and subcooling of the refrigerant may occur as well.

4.2 Bubble point

The saturation temperature of the refrigerant liquid at a specified pressure (°C).

This is a free preview. Purchase the entire publication at the link below:

AS/NZS 4776.1.1 : 2008 : EN : COMBINED PDF

-
- ⊙ Looking for additional Standards? Visit SAI Global Infostore
 - ⊙ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-

Need to speak with a Customer Service Representative - Contact Us