



## **High-voltage switchgear and controlgear**

### **Part 102: Alternating current disconnectors and earthing switches (IEC 62271-102:2018, MOD)**



AS 62271.102:2019

This Australian Standard® was prepared by EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 21 October 2019.

This Standard was published on 22 November 2019.

The following are represented on Committee EL-007:

- Australian Industry Group
- Energy Networks Australia
- Engineers Australia
- University of New South Wales

This Standard was issued in draft form for comment as DR AS IEC 62271.102:2019.

This is a free 15 page sample. Access the full version online.

### **Keeping Standards up-to-date**

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

[www.standards.org.au](http://www.standards.org.au)

ISBN 978 1 76072 638 6



## **High-voltage switchgear and controlgear**

### **Part 102: Alternating current disconnectors and earthing switches (IEC 62271-102:2018, MOD)**

Originated as AS 1306—1985 and AS 4298—1995.  
Revised, amalgamated and redesignated as AS 62271.102—2005.  
Second edition 2019.

#### **COPYRIGHT**

© IEC 2019 — All rights reserved  
© Standards Australia Limited 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

## Preface

This Standard was prepared by the Standards Committee EL-007, Power Switchgear, to supersede AS 62271.102—2005, *High voltage switchgear and controlgear — Part 102: Alternating current disconnectors and earthing switches (IEC 62271-102, Ed.1.0 (2003) MOD)*.

The objective of this Standard is to specify the applications to alternating current disconnectors and earthing switches, designed for indoor and outdoor installations for nominal voltages above 1 000 V and for service frequencies up to and including 60 Hz.

This Standard also applies to the following:

- (a) Operating devices of the above disconnectors and earthing switches and their auxiliary equipment.
- (b) Switching devices having disconnecting and/or earthing functionalities apart from other functions, such as high-speed earthing switch, circuit-breaker and switch-disconnector.

This Standard does not cover disconnectors in which the fuse forms an integral part.

This Standard is an adoption with national modifications, and has been reproduced from, IEC 62271-102:2018, *High-voltage switchgear and controlgear — Part 102: Alternating current disconnectors and earthing switches*.

The modifications are additional requirements and are set out in Appendix ZZ, which has been added at the end of the source text.

Appendix ZZ lists the variations to IEC 62271-102:2018 for the application of this Standard in Australia.

As this document has been reproduced from an International Standard, the following applies:

- (i) In the source text “this part of IEC 62271” should read “this Australian Standard”.
- (ii) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

This is a free 15 page sample. Access the full version online.

NOTES

## CONTENTS

FOREWORD .....	9
1 Scope .....	12
2 Normative references .....	12
3 Terms and definitions .....	13
3.1 General terms and definitions .....	13
3.2 Assemblies of switchgear and controlgear .....	14
3.3 Parts of assemblies .....	14
3.4 Switching devices .....	14
3.5 Parts of switching devices .....	15
3.6 Operation .....	18
3.7 Characteristic quantities .....	19
3.8 Index of definitions .....	24
4 Normal and special service conditions .....	26
5 Ratings .....	26
5.1 General .....	26
5.2 Rated voltage ( $U_r$ ) .....	27
5.3 Rated insulation level ( $U_d$ , $U_p$ , $U_s$ ) .....	27
5.4 Rated frequency ( $f_r$ ) .....	27
5.5 Rated continuous current ( $I_r$ ) .....	27
5.6 Rated short-time withstand current ( $I_k$ ) .....	27
5.7 Rated peak withstand current ( $I_p$ ) .....	27
5.8 Rated duration of short-circuit ( $t_k$ ) .....	28
5.9 Rated supply voltage of auxiliary and control circuits ( $U_a$ ) .....	28
5.10 Rated supply frequency of auxiliary circuits and control circuits .....	28
5.11 Rated pressure of compressed gas supply for controlled pressure systems .....	28
5.11.101 Rated pressure of compressed gas supply for insulation and/or switching .....	28
5.11.102 Rated pressure of compressed gas supply for operation .....	28
5.101 Rated short-circuit making current ( $I_{ma}$ ) .....	28
5.102 Classification of earthing switches for short-circuit making .....	28
5.103 Rated contact zone .....	29
5.104 Rated static mechanical terminal load .....	29
5.105 Classification of disconnectors for mechanical endurance .....	30
5.106 Classification of earthing switches for mechanical endurance .....	31
5.107 Rated ice-coating .....	31
5.108 Rated values of disconnectors for bus-transfer current switching .....	31
5.108.1 Rated bus-transfer current .....	31
5.108.2 Rated bus-transfer voltage .....	32
5.109 Classification and rated values of earthing switches for induced current switching .....	32
5.110 Classification and rated values of disconnectors for bus-charging current switching .....	33
6 Design and construction .....	34
6.1 Requirements for liquids in disconnectors and earthing switches .....	34
6.2 Requirements for gases in disconnectors and earthing switches .....	34
6.3 Earthing of disconnectors and earthing switches .....	34

6.4	Auxiliary and control equipment and circuits .....	35
6.5	Dependent power operation .....	35
6.6	Stored energy operation.....	35
6.7	Independent unlatched operation (independent manual or power operation) .....	35
6.8	Manually operated actuators .....	35
6.9	Operation of releases.....	35
6.10	Pressure/level indication .....	35
6.11	Nameplates.....	35
6.12	Locking devices .....	38
6.13	Position indication.....	38
6.14	Degree of protection provided by enclosures .....	38
6.15	Creepage distances for outdoor insulators .....	38
6.16	Gas and vacuum tightness.....	38
6.17	Tightness for liquid systems.....	38
6.18	Fire hazard (flammability) .....	38
6.19	Electromagnetic compatibility (EMC).....	38
6.20	X-ray emission .....	38
6.21	Corrosion .....	38
6.22	Filling levels for insulation, switching and/or operation .....	39
6.101	Particular requirements for earthing switches.....	39
6.102	Requirements in respect of the isolating distance of disconnectors .....	39
6.103	Mechanical strength.....	39
6.104	Operation of disconnectors and earthing switches – Position of the movable contact system and its indicating and signalling devices .....	40
6.104.1	Securing of position .....	40
6.104.2	Additional requirements for power-operated mechanisms .....	40
6.104.3	Indication and signalling of position .....	40
6.105	Maximum force required for manual (dependent or independent) operation.....	41
6.105.1	General .....	41
6.105.2	Operation requiring more than one revolution .....	42
6.105.3	Operation requiring up to one revolution .....	42
6.106	Dimensional tolerances.....	42
6.107	Earthing switches with short-circuit making current capability .....	42
7	Type tests .....	42
7.1	General.....	42
7.1.1	Basics .....	42
7.1.2	Information for identification of test objects.....	44
7.1.3	Information to be included in type test reports .....	44
7.2	Dielectric tests .....	44
7.2.1	General .....	44
7.2.2	Ambient air conditions during tests .....	44
7.2.3	Wet test procedure .....	44
7.2.4	Arrangement of the equipment.....	44
7.2.5	Criteria to pass the test .....	45
7.2.6	Application of the test voltage and test conditions.....	45
7.2.7	Tests of disconnectors and earthing switches of $U_T \leq 245$ kV.....	45
7.2.8	Test of disconnectors and earthing switches of $U_T > 245$ kV .....	45
7.2.9	Artificial pollution tests for outdoor insulators.....	45
7.2.10	Partial discharge tests .....	46

7.2.11	Dielectric tests on auxiliary and control circuits .....	46
7.2.12	Voltage test as condition check .....	46
7.3	Radio interference voltage (RIV) test .....	46
7.4	Resistance measurement .....	46
7.5	Continuous current tests .....	46
7.6	Short-time withstand current and peak withstand current tests .....	46
7.6.1	General .....	46
7.6.2	Arrangement of the disconnectors and earthing switches and of the test circuit .....	46
7.6.3	Test current and duration .....	52
7.6.4	Conditions of disconnectors and earthing switches after test .....	52
7.7	Verification of the protection .....	53
7.8	Tightness tests .....	53
7.9	Electromagnetic compatibility tests (EMC) .....	53
7.10	Additional tests on auxiliary and control circuits .....	53
7.11	X-ray radiation test for vacuum interrupters .....	53
7.101	Test to prove the short-circuit making performance of earthing switches .....	54
7.101.1	General test conditions .....	54
7.101.2	Arrangement of the earthing switch for tests .....	54
7.101.3	Test frequency .....	54
7.101.4	Test voltage .....	54
7.101.5	Test short-circuit making current .....	55
7.101.6	Test circuits .....	55
7.101.7	Test procedures .....	55
7.101.8	Behaviour of earthing switches when making short-circuit currents .....	56
7.101.9	Condition of earthing switch after short-circuit making tests .....	56
7.101.10	Invalid tests .....	57
7.101.11	Type test reports .....	57
7.102	Operating and mechanical endurance tests .....	58
7.102.1	General test conditions .....	58
7.102.2	Contact zone test .....	58
7.102.3	Mechanical endurance test .....	61
7.102.4	Operation during the application of rated static mechanical terminal loads .....	63
7.102.5	Extended mechanical endurance tests .....	64
7.102.6	Testing of mechanical interlocking devices .....	65
7.103	Operation under severe ice conditions .....	65
7.103.1	General .....	65
7.103.2	Test arrangement .....	65
7.103.3	Test procedure .....	66
7.104	Low- and high-temperature tests .....	67
7.104.1	General .....	67
7.104.2	Measurement of ambient air temperature .....	68
7.104.3	Low-temperature test .....	68
7.104.4	High-temperature test .....	70
7.105	Tests to verify the proper functioning of the position-indicating device .....	70
7.105.1	General .....	70
7.105.2	Tests on the power kinematic chain and the position-indicating kinematic chain .....	71
7.106	Bus-transfer current switching tests on disconnectors .....	71



7.106.1	General .....	71
7.106.2	Making and breaking tests .....	71
7.107	Induced current switching tests on earthing switches .....	75
7.107.1	General .....	75
7.107.2	Arrangement of the earthing switch for tests .....	75
7.107.3	Earthing of test circuit and earthing switch .....	76
7.107.4	Test frequency .....	76
7.107.5	Test voltage .....	76
7.107.6	Test currents .....	76
7.107.7	Test circuits .....	76
7.108	Bus-charging current switching tests on disconnectors .....	81
7.108.1	General .....	81
7.108.2	Test duties .....	82
7.108.3	Arrangement of the disconnector for tests .....	82
7.108.4	Test frequency .....	82
7.108.5	Test voltages for making and breaking tests .....	83
7.108.6	Test circuits for making and breaking tests .....	84
7.108.7	Performance of making and breaking tests .....	86
7.108.8	Behaviour of the disconnector during making and breaking tests .....	86
7.108.9	Condition after test .....	87
7.108.10	Type test reports .....	87
7.108.11	Requirements for $U_{TVE}$ measurements .....	88
8	Routine tests .....	88
8.1	General .....	88
8.2	Dielectric test on the main circuit .....	88
8.3	Tests on auxiliary and control circuits .....	89
8.4	Measurement of the resistance of the main circuit .....	89
8.5	Tightness test .....	89
8.6	Design and visual checks .....	89
8.101	Mechanical operating tests .....	89
8.102	Verification of earthing function .....	90
9	Guide to the selection of disconnectors and earthing switches (informative) .....	90
9.1	General .....	90
9.2	Selection of rated values .....	91
9.2.101	General .....	91
9.2.102	Selection of rated voltage and rated insulation level .....	91
9.2.103	Selection of rated continuous current .....	91
9.2.104	Selection of rated contact zone .....	91
9.2.105	Selection of rated static mechanical terminal load .....	92
9.2.106	Selection of a bus-transfer current switching capability for disconnectors of $U_r > 52$ kV .....	92
9.2.107	Selection of an induced-current switching capability for earthing switches of $U_r > 52$ kV .....	92
9.2.108	Selection of rated short-time withstand current and of rated duration of short-circuit .....	92
9.2.109	Selection of rated peak withstand current and of rated short-circuit making current for earthing switches .....	93
9.2.110	Selection of short-circuit making capability for earthing switches .....	93
9.3	Cable-interface considerations .....	93

9.4	Continuous or temporary overload due to changed service conditions.....	93
9.5	Environmental aspects.....	93
9.5.101	Local environmental conditions.....	93
10	Information to be given with enquiries, tenders and orders (informative).....	94
10.1	General.....	94
10.2	Information with enquiries and orders.....	94
10.3	Information with tenders.....	95
11	Transport, storage, installation, operating instructions, and maintenance.....	96
11.1	General.....	96
11.2	Conditions during transport, storage and installation.....	96
11.3	Installation.....	96
11.4	Operation.....	97
11.5	Maintenance.....	97
12	Safety.....	97
12.1	General.....	97
12.2	Precautions by manufacturers.....	97
12.3	Precautions by users.....	97
13	Influence of the product on the environment.....	97
	Annex A (informative) Test voltage for the most disadvantageous dielectric position of an earthing switch during operation (minimum temporary clearance).....	98
	Annex B (informative) Current-switching capability required of disconnectors and earthing switches.....	99
B.1	Bus-transfer current switching capability of disconnectors.....	99
B.2	Bus-charging current switching capability of disconnectors.....	99
B.3	Induced current-switching capability of earthing switches.....	100
	Annex C (normative) Tolerances on test quantities for type tests.....	101
	Annex D (normative) Alternative test methods for short-circuit current making tests.....	103
D.1	General.....	103
D.2	Alternative methods.....	103
D.2.1	Synthetic test method with both rated voltage and rated short-circuit current.....	103
D.2.2	Test methods with reduced voltage.....	103
	Annex E (informative) Extension of validity of type tests.....	105
E.1	General.....	105
E.2	Dielectric tests.....	105
E.3	Short-time withstand current tests.....	105
E.4	Short-circuit making performance of earthing switches.....	105
E.5	Operating and mechanical endurance tests.....	105
E.6	Bus-transfer current switching tests on disconnectors.....	105
E.7	Induced current switching tests on earthing switches.....	106
	Bibliography.....	107
	Figure 1 – Position indicating/signalling device(s).....	40
	Figure 2 – Three-phase test arrangement for disconnectors and earthing switches.....	48
	Figure 3 – Single-phase test arrangement for disconnectors with a horizontal isolating distance and for earthing switches of $U_T > 52$ kV, to be used with flexible or with rigid conductors.....	49

Figure 4 – Single-phase test arrangement for divided support disconnectors (earthing switches) of $U_T > 52$ kV with a vertical isolating distance, to be used with flexible conductors .....	50
Figure 5 – Single-phase test arrangement for divided support disconnectors (earthing switches) of $U_T > 52$ kV with a vertical isolating distance, to be used with rigid conductors .....	51
Figure 6 – Fixed contact parallel to support .....	59
Figure 7 – Fixed contact perpendicular to support .....	60
Figure 8 – Example of the application of rated static mechanical terminal loads to a (divided support) pantograph disconnector (or earthing switch) .....	61
Figure 9 – Example of the application of rated static mechanical terminal loads to a two-column disconnector .....	62
Figure 10 – Test sequences for low and high temperature tests .....	68
Figure 11 – Example of test circuit for bus-transfer current switching tests .....	73
Figure 12 – Test circuit for electromagnetically induced current switching tests .....	77
Figure 13 – Test circuits for electrostatically induced current-switching tests .....	79
Figure 14 – Test circuit for test duty 1 .....	83
Figure 15 – Typical voltage waveform (Including VFT and FT components) .....	85
Figure 16 – Test circuit for test duty 2 .....	85
Figure 17 – Test circuit for test duty 3 .....	86
Figure B.1 – Examples of resistor-fitted disconnectors .....	100
Table 1 – Classification of earthing switches for short-circuit making .....	28
Table 2 – Preferred contact zones for "fixed" contacts supported by flexible conductors .....	29
Table 3 – Preferred contact zones for "fixed" contacts supported by rigid conductors .....	29
Table 4 – Preferred static mechanical terminal loads .....	30
Table 5 – Classification of disconnectors for mechanical endurance .....	31
Table 6 – Classification of earthing switches for mechanical endurance .....	31
Table 7 – Rated bus-transfer voltages of disconnectors .....	32
Table 8 – Classification of earthing switches for induced-current switching .....	32
Table 9 – Rated induced currents and voltages .....	33
Table 10 – Classification of disconnectors for bus-charging switching .....	34
Table 11 – Standard rated bus-charging currents .....	34
Table 12 – Product information .....	36
Table 13 – List of type tests .....	43
Table 14 – Power frequency withstand voltages .....	45
Table 15 – Requirements on the instant of making .....	56
Table 16 – Invalid tests .....	57
Table 17 – Standard values of recovery voltages for electromagnetically induced current breaking tests .....	78
Table 18 – Test circuit capacitances ( $C_1$ values) for electrostatically induced current switching tests .....	80
Table 19 – Test voltages for making and breaking tests .....	83
Table 20 – Number of tests .....	86

Table 21 – Power frequency voltage tests .....	89
Table B.1 – Average impedances .....	99
Table C.1 – Tolerances on test quantities for type tests .....	101

This is a free 15 page sample. Access the full version online.

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 102: Alternating current disconnectors and earthing switches**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-102 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2001, Amendment 1:2011 and Amendment 2:2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) new numbering according to IEC 17/1025/RQ to harmonize with ISO/IEC Directives, Part 2, and IEEE Std. C37.100.1;
- b) clause numbering has been aligned with IEC 62271-1:2017;
- c) the Scope has been extended to cover all indoor and outdoor installations. Consideration of switching devices having disconnecting and/or earthing switch functionalities, apart from other functions, are also covered by this document;

- d) ratings have been moved from Annexes B, C and E to Clause 5; the order of the subclauses now corresponds to the order of subclauses in Clause 7;
- e) new rating values for bus-transfer current and bus-transfer voltage have been assigned;
- f) new class of mechanical endurance for earthing switches has been added (M1);
- g) subclause "Rated values of electrical endurance for earthing switches" is now called "Classification of earthing switches for short-circuit making capability";
- h) new subclause with ratings for ice-coating has been added;
- i) new subclause with classification of bus-charging switching capability has been added;
- j) new withstand requirements for interlocking devices have been added;
- k) the way to comply with the requirements of the isolating distance of disconnectors has been modified;
- l) design and construction requirements for position-indicating devices have been modified, aligning the requirements for position indication and signalling;
- m) the value of the operating force has been changed;
- n) the test procedures and validation criteria have been revised and modified where necessary;
- o) requirements for applied voltage during single-phase test on non-simultaneous closing earthing switches have been changed;
- p) non-verifiable requirements have been deleted;
- q) a new subclause has been added for testing mechanical interlocking devices;
- r) the high- and low-temperature test is mandatory if the temperature limits for the service conditions of the apparatus (defined by the manufacturer) are above +40 °C or below –5 °C, and a more detailed testing procedure is given;
- s) the testing procedure to verify the proper functioning of the position-indicating device allows a more practicable testing for every technology used;
- t) a new Annex B has been added with title: "Current-switching capability required of disconnectors and earthing switches";
- u) a new Annex C has been added with title: "Tolerances on test quantities for type tests";
- v) a new Annex E has been added with title: "Extension of validity of type tests".

This standard is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable, unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses, except annexes, is used as in IEC 62271-1:2017. Additional subclauses are numbered from 101.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
17A/1173/FDIS	17A/1180/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

This is a free preview. Purchase the entire publication at the link below:

**AS 62271.102 : 2019 : EN : COMBINED PDF**

- 
- ⤵ Looking for additional Standards? Visit SAI Global Infostore
  - ⤵ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
- 

Need to speak with a Customer Service Representative - Contact Us