

Australian/New Zealand Standard™

**Electrical installations—Selection of
cables**

**Part 1.2: Cables for alternating voltages
up to and including 0.6/1 kV—Typical
New Zealand conditions**



AS/NZS 3008.1.2:2017

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-001, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 1 December 2016 and by the New Zealand Standards Approval Board on 17 November 2016.

This Standard was published on 2 February 2017.

The following are represented on Committee EL-001:

Australian Building Codes Board
Australian Industry Group
Communications, Electrical and Plumbing Union—Electrical Division
Consumers Federation of Australia
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Electrical Safety Organisation, New Zealand
ElectroComms and Energy Utilities Industries Skills Council
Energy Networks Association
Engineers Australia
Institute of Electrical Inspectors
Master Electricians Australia
Ministry of Business, Innovation and Employment, New Zealand
National Electrical and Communications Association
National Electrical Switchboard Manufacturers Association
New Zealand Council of Elders
New Zealand Electrical Institute
New Zealand Manufacturers and Exporters Association
Trade and Investment, NSW

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia Web Site at www.standards.org.au or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 3008.1.2:2015.

Australian/New Zealand Standard™

Electrical installations—Selection of cables

Part 1.2: Cables for alternating voltages up to and including 0.6/1 kV—Typical New Zealand conditions

Originated in Australia as AS 3008.1—1984.
Second edition 1989.
Jointly revised and redesignated AS/NZS 3008.1.2:1998.
Previous edition 2010.
This edition 2017.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

ISBN 978 1 76035 657 6

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-001, Wiring Rules, to supersede AS/NZS 3008.1.2:2010, *Electrical installations—Selection of cables*, Part 1.2: *Cables for alternating voltages up to and including 0.6/1 kV—Typical New Zealand conditions*. This Standard is applicable to New Zealand installation conditions where the nominal ambient air and soil temperatures are 30°C and 15°C, respectively. AS/NZS 3008.1.1 is applicable to Australian installation conditions where the nominal air and soil temperatures are 40°C and 25°C respectively. Each Part is a complete Standard and requires no reference to the other.

This Standard deals with cables for use with alternating voltages over 1 kV.

The objective of this Standard is to specify current-carrying capacity, voltage drop and short-circuit temperature rise of cables, to provide a method of selection for those types of electric cables and methods of installation that are in common use at working voltages up to and including 0.6/1 kV at 50 Hz a.c.

This Standard differs from the 2010 edition as follows:

- (a) Economic optimization for cable selection recommendations, including a new example in Appendix A.
- (b) A new definition for Circuit.
- (c) Cable core cross sections have been updated for the following:
 - (i) Figure 1.
 - (ii) Table 3(1).
 - (iii) Table 3(2).
 - (iv) Table 3(4).
 - (v) Table 10.
 - (vi) Table 11.
 - (vii) Table 12.
 - (viii) Table 13.
 - (ix) Table 14.
 - (x) Table 15.
 - (xi) Table 17.
 - (xii) Table 26(2).
- (d) New notes to Tables 30, 31, 40, 41, 43, 44, 46, 47, 50 and 51 have been included.
- (e) Changes to derating factors in Table 23.
- (f) Circuit recommendations for low magnetic fields added to Appendix D.

In the preparation of this Standard, reference was made to IEC 60287 and acknowledgement is made of the assistance received from that source.

Statements expressed in mandatory terms in notes to Tables and Figures are deemed to be requirements of this Standard.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND APPLICATION	
1.1 SCOPE.....	5
1.2 APPLICATION	5
1.3 ALTERNATIVE SPECIFICATIONS	6
1.4 REFERENCED AND RELATED DOCUMENTS.....	6
1.5 DEFINITIONS.....	7
SECTION 2 CABLE SELECTION PROCEDURE	
2.1 GENERAL.....	9
2.2 SELECTION PROCESS.....	9
2.3 DETERMINATION OF MINIMUM CABLE SIZE BASED ON CURRENT-CARRYING CAPACITY CONSIDERATIONS.....	9
2.4 DETERMINATION OF MINIMUM CABLE SIZE BASED ON VOLTAGE DROP CONSIDERATIONS.....	10
2.5 DETERMINATION OF MINIMUM CABLE SIZE BASED ON THE SHORT-CIRCUIT TEMPERATURE CONSIDERATIONS	11
2.6 DETERMINATION OF CABLE SIZE BASED ON THE ECONOMIC OPTIMIZATION CONSIDERATIONS (OPTIONAL)	11
SECTION 3 CURRENT-CARRYING CAPACITY	
3.1 RATINGS.....	12
3.2 TYPES OF CONDUCTORS.....	12
3.3 TYPES OF CABLE	14
3.4 INSTALLATION CONDITIONS.....	16
3.5 EXTERNAL INFLUENCES ON CABLES	19
SECTION 4 VOLTAGE DROP	
4.1 GENERAL.....	91
4.2 DETERMINATION OF VOLTAGE DROP FROM MILLIVOLTS PER AMPERE METRE.....	91
4.3 DETERMINATION OF VOLTAGE DROP FROM CIRCUIT IMPEDANCE	92
4.4 DETERMINATION OF VOLTAGE DROP FROM CABLE OPERATING TEMPERATURE	94
4.5 DETERMINATION OF VOLTAGE DROP FROM LOAD POWER FACTOR.....	94
4.6 DETERMINATION OF VOLTAGE DROP IN UNBALANCED MULTIPHASE CIRCUITS	96
SECTION 5 SHORT-CIRCUIT PERFORMANCE	
5.1 GENERAL.....	120
5.2 FACTORS GOVERNING THE APPLICATION OF THE TEMPERATURE LIMITS.....	120
5.3 CALCULATION OF PERMISSIBLE SHORT-CIRCUIT CURRENTS.....	121
5.4 INFLUENCE OF METHOD OF INSTALLATION.....	122
5.5 MAXIMUM PERMISSIBLE SHORT-CIRCUIT TEMPERATURES	122

This is a free preview. Purchase the entire publication at the link below:

AS/NZS 3008.1.2 : 2017 : EN PDF

- ⊙ Looking for additional Standards? Visit SAI Global Infostore
- ⊙ Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation

Need to speak with a Customer Service Representative - Contact Us